



वसंतराव नाईक राज्य कृषी विस्तार व्यवस्थापन प्रशिक्षण संस्था



व्हीआयपी रोड, धरमपेठ, नागपूर - ४४००१०

E Mail - sameti123@yahoo.co.in

Phone- 0712 2555999, 2541944

जा. क्रं. वनामती/ बांधकाम/ 3806/2023
नागपूर दि. ०९/११/२०२३.


प्रति,

विषय- वनामती परिसरातील वसंतराव नाईक स्मृती सभागृह तसेच वर्षा वसितगृह येथील विद्युत यंत्रणेच्या दुरुस्तीकरिता दरपत्रके मागविण्याबाबत.

उपरोक्त विषयानुसार वनामती परिसरातील वसंतराव नाईक स्मृती सभागृह तसेच वर्षा वसितगृह येथील विद्युत यंत्रणेची सोबत जोडलेल्या प्रपत्राप्रमाणे दुरुस्ती करावयाची आहे.

सदर दरपत्रक सुचना प्राप्त होताच संस्थेत प्रत्यक्ष भेट देऊन कामाची पाहणी करून दरपत्रक कार्यालयास मा. संचालक, वनामती नागपूर या नावाने दिनांक ०७.११.२०२३ रोजी कार्यालयीन वेळेपर्यंत सादर करावे. दरपत्रकासोबत पॅन कार्ड/जीएसटी/नोंदणी प्रमाणपत्रची झेरॉक्स प्रत जोडावी. उशिरा येणा-या दरपत्रकाचा विचार केला जाणार नाही.

सहपत्र- कामाच्या विवरणाचे प्रपत्र


अपर संचालक

वसंतराव नाईक राज्य कृषी विस्तार
व्यवस्थापन प्रशिक्षण संस्था, नागपूर.

प्रत-

१. कार्यालयीन नोटीस बोर्ड
२. वनामती कार्यालयाची वेबसाईट www.vanamati.in

**Name of work :- Repairs to Electrical Installation at Auditorium and
Varsha Hostel, VANAMATI, Nagpur.**

Item No.	Description	Qty/per	Rate	Amount
1	S/E LED Panel light (600 mm X 600 mm) max 35 W--- complete with 3 years warranty	24 nos	-	
2	S/E LED Panel light max 18 W--- complete with 3 years warranty	15 nos	-	
3	S/E mains with 2 X 1.5 sq mm FRLSH copper PVC insulated wire--- complete	100 rmt	-	
4	S/E and terminating FRXLPE insulated cable 1100 V, 4 core 16 sqmm--- complete	45 rmt	-	
5	S/E (TPNDB) 36 poles/12 ways (Vertical busbar type)--- complete	1 nos	-	
6	S/E and marking (TPMCB) 40 A to 63 A --- complete	3 nos	-	
7	S/E and marking (SPMCB) 06 A to 32 A, C series - --complete	10 nos	-	
8	S/E and terminating XLPE armoured cable 3.5 core, 50 sqmm--- complete	30 rmt	-	
9	S/E and terminating XLPE armoured cable 3.5 core, 35 sqmm--- complete (labour only)	30 rmt	-	
10	S/E aluminium lugs for cable 50 sqmm --- complete	16 nos	-	
11	P/E 3 pole MCCB upto 100 A , 415 V with short circuit rating 25 kA---complete	1 nos	-	
12	S/E FRP box of size 250 X 200 X100 mm, 2.7 mm thick --- complete	1 nos	-	


Civil Engineer

VANAMATI, Nagpur.